



**Office of the District Fire Officer,  
Banashankari Fire Station,  
Karnataka Fire & Emergency Services,  
Banashankari 2<sup>nd</sup> Stage, Bengaluru-560 070.**



Dated: 17-03-2025

No. 14/DFO/BFS/RFSCR-School/2025

**ANNEXURE – 1**

**Group - B Educational Building**

NBC-2016, Part-4, Table 7(11) 3.1.3 Group B Educational Buildings Sub Division B1 & B2.

(These condition are indicative and not exclusive all relevant provisions related to fire and life safety of NBC-2016 are mandatory).

-----

To,  
Sri Sharada Vidyanikethana,  
(Sri M.S.Lingegowda Education Trust)  
Sy.No.15, Khatha No: 15, 1<sup>st</sup> Main, 2nd Cross,  
ISRO Layout, Bikasipura,  
Bengaluru-560 078.

Sir,

**Sub :** Issue of "**Renewal Fire safety Compliance Report**" with respect of fire prevention, fire fighting and evacuation measures required at **M/s. Sri Sharada Vidyanikethana**, Sy.No.15, Khatha No:15, 1<sup>st</sup> Main, 2nd Cross, ISRO Layout, Bikasipura, Bengaluru-560 078. - reg.

**Ref :**

- 1) CFO East Office FSR No.215/CFO/Bng-East/FSR/2018 Dt:17-04-2018.
- 2) This Office FSCR No.11/DFO/BFS/2022 Date:18-06-2022
- 3) This Office RFSCR No.89/DFO/BFS/RFSCR/2023 Date:09-12-2023
- 4) Your request letter dated: 07-02-2025.
- 5) FSO Office Inspection Report No:- 06/FSO/BFS/2025, Date:- 10-03-2025

<<<<>>

With reference to the above cited subject, as per above Reference, a conditional Fire Safety Compliance Report, was issued to the Premises of "**M/s. Sri Sharada Vidyanikethana**, Sy.No.15, Khatha No:15, 1<sup>st</sup> Main, 2nd Cross, ISRO Layout, Bikasipura, Bengaluru-560 078 with a condition to fulfill the recommendations and compliance the same within three months.

With reference to cited (4) above the management of **M/s. Sri Sharada Vidyanikethana**, Sy.No.15, Khatha No:15, 1<sup>st</sup> Main, 2nd Cross, ISRO Layout, Bikasipura, Bengaluru-560 078 had Requested for the Renewal Fire Safety Compliance Report from our department. In this regard Fire Station Officer, Banashankari Fire Station inspected on 07-03-2025 with respect to Fire prevention.

Under the above Circumstance the Karnataka State Fire & Emergency Services Department Is issuing the **Renewal Fire Safety Compliance Report** to **M/s. Sri Sharada Vidyanikethana**, Sy.No.15, Khatha No:15, 1<sup>st</sup> Main, 2nd Cross, ISRO Layout, Bikasipura, Bengaluru-560 078 Subject to proper maintenance of fire fighting installations, in the good working condition.



*This Fire Safety compliance Report is issued from the fire prevention and fire fighting point of view Karnataka State Fire & Emergency Services Department is not responsible for the ownership of the land, its location and other disputes, which may arise in due course.*

*"In case the fire prevention and fire fighting measures installed in the building as per the recommendation of the department are not maintained in good working condition, if the evacuation measures are not properly followed and if any additional construction work is taken up in the building/premises, This Fire Safety compliance Report deemed to be cancelled and necessary legal action will be initiated against developer/management/ tenant. And also separate NOC has to be obtained from the department for storage of Chemicals, Solvents, Petroleum products(Petrol/Diesel), LPG etc., in the building/premises."*

**"This Fire Safety Compliance Report is valid for Only Two Year from the date of issue and it is renewable".**

Your's Faithfully

  
17/03/2025  
**DISTRICT FIRE OFFICER**  
**Banashankari Fire Station**  
**Bangalore - 560 070**